



EVE® 2013 Central European Guideline For Building Air Tightness and Air Permeability

Key

Rating	A	B	F
$m^3/[h.m^2]$at 50 Pascals	First Class	Acceptable*	Failure

Offices	A	B	F
Naturally Ventilated	3	7	10
Mixed Mode	2	5	7
Air Conditioned to B+	2	4	5
Air Conditioned to A+	1	2	3
Air Conditioned AAA	1	1	2

Retail	A	B	F
Anchors	1	3	5
Inlines	1	2	3
Standalone high street	1	2	3
Casual Dining	1	2	3
Circulation Air Conditioned	1	2	5
Circulation Not Conditioned	3	5	7

Warehouse	A	B	F
Dry Storage and Distribution	2	6	7
Chilled Storage and Distribution	0,2	0,5	1
Cold Storage and Distribution	0,1	0,2	0,5



EVE® 2013 Central European Guideline For Building Air Tightness and Air Permeability

Key

Rating	A	B	F
$\text{m}^3/[\text{h}\cdot\text{m}^2]$at 50 Pascals	First Class	Acceptable*	Failure

Hotels	A	B	F
Guest Rooms	1	2	3
Kitchens and Preparation	2	3	7
Circulation Areas Air Conditioned	1	2	3

Public Buildings	A	B	F
Hospitals Mechanically Ventilated	5	7	9
Hospitals Air Conditioned	1	2	4
Libraries	3	5	7
Schools	3	5	7
Museums and Archives	0,5	1,5	2

Private Dwellings	A	B	F
Apartments	2	3	5
Apartment Circulation	3	5	7
Single Family Homes	2	3	5
Air Conditioned Living Space	1	1,5	2
Passive House	0,2	1,0	1,1